## Aquami Monoblock heat pump

AQM60X1 [R14]



## Specification outdoor unit

-				
Model				AQM60X1 R14
EAN Code				5905567602184
Power supply			V-Hz, Ø	220-240-50, 1f
	Capacity		kW	6,35
Heating				
(A7/W35)	Rated input		kW	1,28
	COP			4,95
	Capacity		kW	6,30
Heating	Rated input		kW	1,70
(A7/W45)	COP			3,70
Heating (A7/W55)	Capacity		kW	6,00
	Rated input		kW	2,03
	COP			2,95
Cooling (A35/W18)	Capacity		kW	6,50
	Rated input		kW	1,35
			KVV	
	EER			4,80
Cooling (A35/W7)	Capacity		kW	7,00
	Rated input		kW	2,33
	EER			3,00
	SCOP <sup>(1)</sup>			4,95
Seasonal energy	Rated heat output		kW	6,8
efficiency	Seasonal energy efficiency ratio (ηS)		96	195
LWT at 35°C	Annual energy consumption		kWh	2845
	Seasonal space heating energy efficiency class <sup>(1)</sup>			A+++
				3,52
Seasonal energy efficiency LWT at 55°C	SCOP <sup>(1)</sup>			
	Rated heat output		kW	5,70
	Seasonal energy efficiency ratio (ŋS)		96	137,9
	Annual energy consumption		kWh	3343
	Seasonal space heating energy efficiency class <sup>(1)</sup>			A++
				5,34
SEER	LWT at 7°C			
	LWT at 18°C			8,21
Minimum rated cur	Minimum rated current of the overcurrent circuit breaker with breaker type			B32
Compressor		Туре		Twin rotary inverter compressor DC
				Brushless DC motor / BLDC
Fan		Туре		
	Quantity			1
		Type / GWP		R32 / 675
Refrigerant			kg	1,4
-		Quantity	TCO,eq	0,95
Minimal			-	3×6
Minimal wire pcs and dimension of cords*		pcs × mm <sup>2</sup>		
Bracket spacing (W1×W2×D)		mm	638 x 379 x 401	
Sound pressure level		dB(A)	47,5	
Sound power level		dB(A)	58	
Net dimensions (W×D×H)		(W×D×H)	mm	1295×429×718
Gross dimensions		(W×D×H)	mm	1375×475×885
Net weight / Gross weight		kg	91/112	
	Cooling		٥C	-5-43
Operating outdoor	Heating		٥C	-25~35
temperature	DHW		°C	-25-43
Operation and			-c	
Operation modes				Heating and cooling
Leaving water temperature	Space cooling		°C	5-25
	Space heating		°C	25~65
	DHW (tank)		°C	30~60
	Power supply		V-Hz, Ø	220-240~50, 1f
Electric heater				
	Number of heating stages / Power		pcs / kW	1/3
	Maximum operating current		A	13,5
	Water connections		mm (inch)	33mm (G1* BSP) external
	Pressure relief valve		MPa	0.3
	Condensate drain		mm	16
	Expansion tank	Total volume / Actual volume	I.	8 / 4,8
	Expansion tank			0.3 / 0.1
	Expansion tank	Maximum pressure / Initial pressure	MPa	0101 011
Water circuit		Maximum pressure / Initial pressure	MPa	
Water circuit	Expansion tank Heat exchanger	Maximum pressure / Initial pressure Type		PHE / plate heat exchanger
Water circuit	Heat exchanger	Maximum pressure / Initial pressure	l/min	PHE / plate heat exchanger 6
Water circuit	Heat exchanger Water pump head	Maximum pressure / Initial pressure Type		PHE / plate heat exchanger 6 9
Water circuit	Heat exchanger	Maximum pressure / Initial pressure Type	l/min	PHE / plate heat exchanger 6
Water circuit	Heat exchanger Water pump head	Maximum pressure / Initial pressure Type	l/min	PHE / plate heat exchanger 6 9

(1) Seasonal energy efficiency class measured under average climate conditions.

(1) decayment (2) enclosing class measured on the periodic contained. Notes: DHW – Domestic hot water, LWT – Leaving water temperature The sound pressure level is measured 1m in front of the unit and (1+H)2m (where H is the height of the unit) above the floor in semi-anechoic room. During on-site operation sound pressure levels can be higher as a result of ambient noise. Sound pressure level and sound power level reflect the maximum value tested under three conditions specified respectively in notes A7W35, ΔT=5; A7W55 ΔT=6; relative humidity 85%. The figures specified above refer to the following standards: EN14511; EN14825; EN50564; EN12102; (EU) Np. 811/2013; (EU) No. 813/2013; Journal of Laws 2014 / C 207/02: 2014. The residual current circuit breaker used to protect the electrical circuit of the appliance shall be selected in view of the electrical regulations in force, assuming that the rated residual current is not greater than LMn: 30mA \*The above values apply to supply cables with a maximum length of 20mb. If this value is exceeded, an electrical designer should be consulted.